Northern Arizona University NAU Capstone New Mexico State University District

- Corey Burke
- Elizabeth Griffith
  - Grant Hale
- Daniel McConnell
  - Jack Viola

# Team Composition



**Corey Burke** 

**Primary Roles:** 

Project Manager & CAD

Engineer



#### Elizabeth Griffith

Primary Roles:

Financial Manager & Manufacturing Engineer



#### Grant Hale

**Primary Roles:** 

Test Engineer & Standards and Regulations Manager



#### Daniel McConnell

Primary Roles:

Logistics Manager & Aurora Solar Manager



Jack Viola

Primary Roles:

Battery Manager & OpenDSS Architect

# **Competition Approach**



The Teams Approach was to generate the most amount of energy while staying financially viable The secondary objectives were to minimize losses and have innovative ideas



Met with business professor at NAU

**d**ĭh

Kristin Kettel

# System Design

- 3 sub systems
- Geothermal Substation Ground Mount system (3 MW)
- Pan American Center Solar Parking Awnings (2 MW)
- Hadley Hall Spanish Solar Tiles (164 kW)
- 220 kW Battery storage system





#### Section 1: Conceptual System Design

- Geothermal Substation
  - 3 miles east of campus
  - 30° tilt ground mount system
  - SunPower T5-SPR 310 mono crystalline (Silicone) panels
- 3 Inverters
  - SMA America: SC850CP-US





D model with LIDAR overlay



#### Section 1: Conceptual System Design

- Pan American Center Solar Parking Awnings
  - Pan American Center parking lot
  - 577 shaded parking spaces
  - Extra revenue from parking passes
  - Parking lines need to be repainted in opposite direction
  - SunPower T5-SPR 310 mono crystalline (Silicone) panels
- 2 Inverters
  - SMA America: SC850CP-US



#### Section 1: Conceptual System Design

- Spanish Solar Tiles
  - Hadley Hall
  - Innovative
  - Maintains school style
  - Aesthetically pleasing
  - HanTiles
- 34 Inverters
  - ABB: PVI-3.6-OUTD-S-US-Z-A [208V]



## Section 1: Conceptual System Design



- Saltwater battery system with 580 kWh capacity
  - Wide Charge/discharge range
  - Innovative
  - Pre-optimized package commercially available
  - Grid-tied system with capability of running during grid outage

## Expected Operation

- PV and Battery Reduce peak consumption
- Battery charged by PV system
- Battery discharge when PV stops producing
- Battery discharges during outage



## Expected Operation

- System supplies 31% of the consumption provided
- Solar farm (GSGM) can be expanded when battery storage is more financially viable
- Battery storage costs are expected reduce 21-67% by 2030
- The critical load of 16% is estimated to survive 31% of 2-hour outages



# System Impact Analysis

Power flow modeling in OpenDSS:

- Loss/fault analysis
- Transmision phase shifting
- Base kV mismatch
- Service drops







DIRITOL PA	(2	9)	2	2.2856	(	0.9510)	/_	-111.0	
IRTLOT_PV	(3	0)	3	2.2857	(	0.9517)	1_	129.0	
DIRTLOT PV	(	0)	0	0	(	0)	1	0.0	
-									
LEMENT = "PVSy	/stem.P	V_HAD	DLEY"						
ADLEY_PV	(3	4)	1	2.5187	(	1.049)	1_	31.8	
ADLEY PV	(3	5)	2	2.5195	Ć	1.049)	1	-87.9	
ADLEY PV	(3	6)	3	2.5198	Ċ	1.049)	1	152.2	
ADLEY PV	(	0)	0	0	Ċ	0)	1	0.0	
_							_		
ELEMENT = "PVSy	/stem.P	V_PAF	RKLOT"						
ARKLOT_PV	(3	1)	1	2.406	(	1.002)	1_	27.4	
ARKLOT PV	(3	2)	2	2.4065	(	1.002)	1_	-92.3	
PARKLOT PV	(3	3)	3	2.4063	Ċ	1.002)	1	147.8	
PARKLOT PV	Ċ	0)	0	0	Ċ	0)	1	0.0	
-							-		
ELEMENT = "Stor	age.DI	RTLOT	F_BATT"						
DIRTLOT_PV	(2	8)	1	2.2873	(	0.9523)	1_	8.6	
DIRTLOT PV	(	0)	0	0	Ċ	0)	Ē	0.0	
_						· · · · · · · · · · · · · · · · · · ·	_		





#### System Operation

- Battery Controller
  - **Peak Shaving** dictates when the battery subsystem is charging vs. discharging
  - **Discharge Rate Regulation** extends battery life by preventing overdrawing power
  - **Power Factor Correction** real-time impedance matching to optimize conversion power factor
- Inverter microcontroller
  - Maximum Power Point Tracking (MPPT) stabilizes voltages going to other sub-systems and service loads

New StorageController.dirtlot\_battctl element=Line.L00 ElementList=dirtlot\_batt terminal=1 ~ ModeDischarge=peakshave ModeCharge=Time TimeChargeTrigger=9.5 TimeDischargeTrigger=14.5 ~ kWTarget=300 PFTarget=0.98 %ratekw=30

# Section 3: Financial Model

- PPA Price: \$0.023/kWh (ac)
- Utility charge: \$0.01/kWh (ac)

#### • Battery stacking

- Demand charge reduction
- PV utilization
- ITC
- Backup power
- Carbon offset
- Valuation of resilience premium
  - Modeled University in calculator

System	Internal Rate of Return (IRR)		
Geothermal Substation Ground Mount	19.65%		
PanAmerican Center Solar Parking Awnings	270.15%		
Hadley Hall Spanish Solar Tiles	25.40%		
Battery Storage using REopt Lite	-4.67%		

System	Net Present Value (NPV)		
Geothermal Substation Ground Mount	(\$100,433)		
PanAmerican Center Solar Parking Awnings	\$194,079		
Hadley Hall Spanish Solar Tiles	(\$26,689)		
Battery Storage using REopt Lite	(\$65,048)		
Summary NPV	\$1,909		

System	Customer Net Present Value (NPV)		
Geothermal Substation Ground Mount	(\$3,531,408)		
PanAmerican Center Solar Parking Awnings	(\$2,107,310)		
Hadley Hall Spanish Solar Tiles	(\$203,486)		
Summary NPV	(\$5,842,204)		

# Section 4: Building and Site Plan

- Land Use and Zoning
- Location Suitability and Attractiveness
- District Master Plan
- Other Land Uses and Building Regulations



# Construction and Development Plan

- Permitting and Relevant Code Analysis
- Construction Approach
- Engaging Decision Makers
- Feasibility



#### Innovation

- Solar tiles
  - Functionable and maintains Spanish Renaissance style
  - Located on a high traffic building
- Parking structure
  - Increases shaded spots on campus by 577 spaces
  - Generates annual revenue with parking pass
- Saltwater batteries
  - Easily recyclable
  - Similar capabilities to Lithium Ion



### Optimization Strategy

- PV System
  - Modeled in Aurora Solar and SAM
  - 5.1 MW System
  - Monocrystalline modules
- Battery storage
  - Sizing optimized in REopt Lite
  - Input and modify original PV system size
  - Hospital consumption model used
  - Critical load factor of 16%



QUESTIONS?